

## Nuclides Analysis Result of the Radioactive Materials in the Air at Fukushima Nuclear Power Stations

(Data summarized on May 19)

Place of Sampling	The West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini NPS (Reference)				② Density Limit Specified by the Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
	Time of Sampling	May 18, 2013 7:00 AM - 12:00 PM	May 18, 2013 9:30 AM - 9:40 AM				
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-			1E-03
Cs-134 (Approx. 2 years)	ND	-	ND	-			2E-03
Cs-137 (Approx. 30 years)	ND	-	ND	-			3E-03

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

0.0E-0 is the same as  $0.0 \times 10^0$

Data of other nuclides is under examination.

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits at the west gate of Fukushima Daiichi NPS are as follows.

Volatile; I-131: Approx.  $8E-8$ Bq/cm<sup>3</sup>, Cs-134: Approx.  $2E-7$ Bq/cm<sup>3</sup>, Cs-137: Approx.  $2E-7$ Bq/cm<sup>3</sup>

Particulate; I-131: Approx.  $5E-8$ Bq/cm<sup>3</sup>, Cs-134: Approx.  $1E-7$ Bq/cm<sup>3</sup>, Cs-137: Approx.  $2E-7$ Bq/cm<sup>3</sup>


The detection limits are as follows.

Volatile; I-131: Approx.  $2E-6$ Bq/cm<sup>3</sup>, Cs-134: Approx.  $2E-6$ Bq/cm<sup>3</sup>, Cs-137: Approx.  $2E-6$ Bq/cm<sup>3</sup>

Particulate; I-131: Approx.  $7E-7$ Bq/cm<sup>3</sup>, Cs-134: Approx.  $1E-6$ Bq/cm<sup>3</sup>, Cs-137: Approx.  $9E-7$ Bq/cm<sup>3</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Dust Nuclides Analysis Result: The West Gate of Fukushima Daiichi Nuclear Power Station (Bq/cm<sup>3</sup>)



(Reference) Dust Nuclides Analysis Results of MP-1 at Fukushima Daini NPS (Bq/cm<sup>3</sup>)

