

## Nuclides Analysis Result of the Radioactive Materials in the Air at the Site of Fukushima Daiichi NPS

Unit: Bq/cm<sup>3</sup>

	West side of the construction area No.1 of the Main Anti-earthquake Building	East side of switching station at Unit 1, 2	MP-2 (Monitoring post No.2)
Date of Sampling	Aug 20, 2013	Aug 20, 2013	Aug 20, 2013
Time of sampling	11:40 AM - 12:00 PM	11:30 AM - 11:50 AM	11:58 AM - 12:28 PM
Cs-134(Approx. 2 years)	ND(3.3E-06)	4.6E-06	3.1E-07
Cs-137(Approx.30 years)	ND(4.7E-06)	8.6E-06	4.2E-07

\* 0.0E-0 is the same as 0.0 x 10<sup>-0</sup>

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.