

Reference

### Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 3 Reactor Building < 1/2 >

(Data summarized on August 14)

Place of Sampling	Upper Part of Unit 3 Reactor Building ① (Above the Reactor (Northeast Side)(Downward direction))	Upper Part of Unit 3 Reactor Building ② (Above the Reactor (Northeast Side)(Cross direction))	Upper Part of Unit 3 Reactor Building ③ (Above the Reactor (Northeast Side)(Downward direction))	② Density Limit Specified by the Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)			
Time of Sampling	Aug 3, 2013 8:50 AM - 9:20 AM	Aug 3, 2013 8:50 AM - 9:20 AM	Aug 3, 2013 9:43 AM - 10:13 AM				
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	ND	-	ND	-	9.9E-06	0.00	2E-03
Cs-137 (Approx. 30 years)	1.7E-05	0.01	2.4E-05	0.01	2.0E-05	0.01	3E-03

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE—O is the same as O.O x 10<sup>-0</sup>

Data of other nuclides is under examination.

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows.

Volatile; I-131: Approx. 6E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 2E-5Bq/cm<sup>3</sup>, Cs-137: Approx. 2E-5Bq/cm<sup>3</sup>

Particulate; I-131: Approx. 4E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 8E-6Bq/cm<sup>3</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

## Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 3 Reactor Building < 2/2 >

(Data summarized on August 14)

Place of Sampling	Upper Part of Unit 3 Reactor Building ④ (Above the Reactor (Northeast Side)(Cross direction))	Upper Part of Unit 3 Reactor Building ⑤ (Around the Machine Hatch Opening on the 3rd Floor)	Upper Part of Unit 3 Reactor Building ⑥ (Around the Machine Hatch Opening on the 3rd Floor)	② Density Limit Specified by the Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)			
Time of Sampling	Aug 3, 2013 9:43 AM - 10:13 AM	Aug 3, 2013 10:35 AM - 11:05 AM	Aug 3, 2013 11:20 AM - 11:50 AM				
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )			Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	2.3E-05	0.01	ND	-	ND	-	2E-03
Cs-137 (Approx. 30 years)	5.4E-05	0.02	ND	-	ND	-	3E-03

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE—O is the same as O.O x 10<sup>-O</sup>

Data of other nuclides is under examination.

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows.

Volatile; I-131: Approx. 7E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 2E-5Bq/cm<sup>3</sup>, Cs-137: Approx. 2E-5Bq/cm<sup>3</sup>

Particulate; I-131: Approx. 4E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 8E-6Bq/cm<sup>3</sup>, Cs-137: Approx. 1E-5Bq/cm<sup>3</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.