

Reference
-----------

### Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 3 Reactor Building <1/4>

(Data summarized on September 30)

Place of Sampling	Upper Part of Unit 3 Reactor Building (Above the Reactor (Northeast Side)(Downward direction))	Upper Part of Unit 3 Reactor Building (Above the Reactor (Northeast Side)(Cross direction))	Upper Part of Unit 3 Reactor Building (Above the Reactor (Northeast Side)(Downward direction))	Density Limit Specified by the Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)			
Time of Sampling	Sep 25, 2013 9:33 AM - 10:03 AM	Sep 25, 2013 9:33 AM - 10:03 AM	Sep 25, 2013 12:20 PM - 12:50 PM				
Detected Nuclides (Half-life)	Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor ( / )	Density of Sample (Bq/cm <sup>3</sup> )				
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (Approx. 30 years)	ND	-	ND	-	ND	-	3E-03

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE - O is the same as O.O x 10<sup>0</sup>

Data of other nuclides is under examination.

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows.

Volatile; I-131: Approx. 7E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 1E-5Bq/cm<sup>3</sup>, Cs-137: Approx. 2E-5Bq/cm<sup>3</sup>

Particulate; I-131: Approx. 4E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 8E-6Bq/cm<sup>3</sup>, Cs-137: Approx. 1E-5Bq/cm<sup>3</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

### Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 3 Reactor Building <2/4>

(Data summarized on September 30)

Place of Sampling	Upper Part of Unit 3 Reactor Building (Above the Reactor (Northeast Side)(Cross direction))		Upper Part of Unit 3 Reactor Building (Above the Reactor (West-southwest side)(Downward direction))		Upper Part of Unit 3 Reactor Building (Above the Reactor (West-southwest side)(Cross direction))		Density Limit Specified by the Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
Time of Sampling	Sep 25, 2013 12:20 AM - 12:50 PM		Sep 25, 2013 10:30 AM - 11:00 AM		Sep 25, 2013 10:30 AM - 11:00 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor ( / )	Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor ( / )	Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor ( / )	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	ND	-	3.4E-05	0.02	ND	-	2E-03
Cs-137 (Approx. 30 years)	2.6E-05	0.01	6.4E-05	0.02	ND	-	3E-03

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE - O is the same as O.O x 10<sup>-O</sup>

Data of other nuclides is under examination.

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows.

Volatile; I-131: Approx. 8E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 1E-5Bq/cm<sup>3</sup>, Cs-137: Approx. 2E-5Bq/cm<sup>3</sup>

Particulate; I-131: Approx. 4E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 8E-6Bq/cm<sup>3</sup>, Cs-137: Approx. 1E-5Bq/cm<sup>3</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

### Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 3 Reactor Building <3/4>

(Data summarized on September 30)

Place of Sampling	Upper Part of Unit 3 Reactor Building (Above the Reactor (West-southwest side)(Downward direction))	Upper Part of Unit 3 Reactor Building (Above the Reactor (West-southwest side)(Cross direction))	Upper Part of Unit 3 Reactor Building (Around the Machine Hatch Opening on the 3rd Floor)	Density Limit Specified by the Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)			
Time of Sampling	Sep 25, 2013 1:15 PM - 1:45 PM	Sep 25, 2013 1:15 PM - 1:45 PM	Sep 25, 2013 11:25 AM - 11:55 AM				
Detected Nuclides (Half-life)	Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor ( / )	Density of Sample (Bq/cm <sup>3</sup> )				
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	2.1E-05	0.01	2.2E-05	0.01	1.1E-05	0.01	2E-03
Cs-137 (Approx. 30 years)	4.2E-05	0.01	5.2E-05	0.02	2.3E-05	0.01	3E-03

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE - O is the same as O.O x 10<sup>-O</sup>

Data of other nuclides is under examination.

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows.

Volatile; I-131: Approx. 7E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 2E-5Bq/cm<sup>3</sup>, Cs-137: Approx. 2E-5Bq/cm<sup>3</sup>

Particulate; I-131: Approx. 4E-6Bq/cm<sup>3</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

### Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 3 Reactor Building <4/4>

(Data summarized on September 30)

Place of Sampling	Upper Part of Unit 3 Reactor Building (Around the Machine Hatch Opening on the 3rd Floor)		/		/		Density Limit Specified by the Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
Time of Sampling	Sep 25, 2013 2:15 PM - 2:45 PM		/		/		
Detected Nuclides (Half-life)	Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor ( / )	Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor ( / )	Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor ( / )	
I-131 (Approx. 8 days)	ND	-	/		/		1E-03
Cs-134 (Approx. 2 years)	ND	-	/		/		2E-03
Cs-137 (Approx. 30 years)	1.5E-05	0.01	/		/		3E-03

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE - O is the same as O.O x 10<sup>-O</sup>

Data of other nuclides is under examination.

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows.

Volatile; I-131: Approx. 7E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 1E-5Bq/cm<sup>3</sup>, Cs-137: Approx. 2E-5Bq/cm<sup>3</sup>

Particulate; I-131: Approx. 4E-6Bq/cm<sup>3</sup>, Cs-134: Approx. 8E-6Bq/cm<sup>3</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.