

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area					
	E-1	E-2	E-3	E-4	E-5	E-6
Date of Sampling	Oct 2, 2013	Oct 2, 2013	Oct 2, 2013	Oct 2, 2013	Oct 2, 2013	Oct 2, 2013
Time of sampling	9:48 AM	9:55 AM	10:25 AM	10:15 AM	10:06 AM	12:38 PM
All β	130	64	120	42	28	ND(19)
H-3 (Approx. 12 years)	160,000	400	170	300	2600	300

* Data announced this time is provided in a thick-frame. The other data was announced on October 3.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

