

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013
Time of sampling	10:05 AM	10:15 AM	10:30 AM	10:40 AM	10:50 AM	9:43 AM	11:43 AM	11:33 AM
All β	230	44	75	43	ND(19)	ND(19)	ND(19)	ND(19)
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

