Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

							Unit: Bq/L
	Groundwater around H4 area						
	E-1	E-2	E-3	E-4	E-5	E-6	E-8
Date of Sampling	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013		
Time of sampling	9:35 AM	9:38 AM	10:09 AM	10:01 AM	9:52 AM		
All β	240	18	64	ND(18)	ND(18)		
H-3 (Approx. 12 years)	260,000	380	ND(120)	ND(120)	2,600		

* Data announced this time is provided in a thick-frame. The other data was announced on October 9.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

