

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 16, 2013	Oct 16, 2013	Oct 16, 2013	Oct 16, 2013	Oct 16, 2013	Oct 16, 2013	Oct 16, 2013	Oct 16, 2013
Time of sampling	9:15 AM	9:26 AM	9:35 AM	9:35 AM	9:43 AM	8:55 AM	9:10 AM	9:20 AM
All β	61	ND(17)	89	ND(17)	ND(17)	ND(17)	ND(17)	ND(17)
H-3 (Approx. 12 years)	230,000	420	190	300	2,700	240	800	1,100

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

