

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 17, 2013	Oct 17, 2013	Oct 17, 2013	Oct 17, 2013	Oct 17, 2013	/	/	/
Time of sampling	9:50 AM	9:40 AM	10:45 AM	10:35 AM	10:20 AM	/	/	/
All β	400,000	25	29	ND(18)	18	/	/	/
H-3 (Approx. 12 years)	790,000	330	150	140	2,800	/	/	/

* Data announced this time is provided in a thick-frame. The other data was announced on October 17.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

