

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	/	/	/
Time of sampling	12:19 PM	11:56 AM	11:10 AM	11:21 AM	11:37 AM	/	/	/
All β	230,000	ND(17)	ND(17)	ND(17)	ND(17)	/	/	/
H-3 (Approx. 12 years)	340,000	340	260	180	2,200	/	/	/

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

