

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 22, 2013	Oct 22, 2013	Oct 22, 2013	Oct 22, 2013	Oct 22, 2013			
Time of sampling	11:00 AM	11:05 AM	11:15 AM	11:25 AM	11:35 AM			
All $\beta$	230,000	54	35	61	ND(18)			
H-3 (Approx. 12 years)	290,000	370	220	230	2,100			

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

