

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 23, 2013	Oct 23, 2013	Oct 23, 2013	Oct 23, 2013	Oct 23, 2013	Oct 23, 2013	Oct 23, 2013	Oct 23, 2013
Time of sampling	11:26 AM	11:15 AM	10:53 AM	10:42 AM	10:32 AM	9:45 AM	10:15 AM	10:04 AM
All $\beta$	200,000	31	53	29	26	31	ND(17)	ND(19)
H-3 (Approx. 12 years)	240,000	380	210	270	2,000	260	710	1,300

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

