

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 25, 2013	Oct 25, 2013	Oct 25, 2013	Oct 25, 2013	Oct 25, 2013			
Time of sampling	10:03 AM	9:48 AM	9:35 AM	9:21 AM	9:10 AM			
All β	230,000	ND(19)	29	ND(19)	ND(19)			
H-3 (Approx. 12 years)	230,000	360	320	330	2,000			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

