

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
November 7, 2013
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area								
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-10
Date of Sampling	Nov 5, 2013	Nov 5, 2013	Nov 5, 2013	Nov 5, 2013	Nov 5, 2013				
Time of sampling	9:23 AM	9:12 AM	9:04 AM	8:55 AM	8:45 AM				
All β	350,000	110	29	ND(21)	ND(21)				
H-3 (Approx. 12 years)	200,000	350	410	800	2,400				

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5
All β	400,000 [10/17]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5]	440 [11/3]	1,000 [11/4]	2,800 [10/4] [10/17]

	E-6	E-7	E-8	E-10
All β	46 [9/20]	ND	17 [10/3]	24 [11/3]
H-3 (Approx. 12 years)	340 [9/25] [10/9]	840 [10/9]	1,500 [10/9]	6,700 [11/3]

Unit: Bq/L, sampling date is provided in parentheses.

