

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
November 12, 2013
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area								
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-10
Date of Sampling	Nov 10, 2013	Nov 10, 2013	Nov 10, 2013	Nov 10, 2013	Nov 10, 2013				
Time of sampling	11:18 AM	11:08 AM	10:58 AM	10:46 AM	10:35 AM				
All β	710,000	18	47	ND(17)	ND(17)				
H-3 (Approx. 12 years)	270,000	460	490	1,100	3,100				

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5
All β	550,000 [11/9]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5]	730 [11/7]	1,200 [11/8] [11/9]	3,000 [11/9]

	E-6	E-7	E-8	E-10
All β	46 [9/20]	ND	17 [10/3]	28 [11/6]
H-3 (Approx. 12 years)	340 [9/25] [10/9]	840 [10/9]	1,900 [11/6]	7,700 [11/6]

Unit: Bq/L, sampling date is provided in parentheses.

