

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
November 19, 2013
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area								
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-10
Date of Sampling	Nov 17, 2013	Nov 17, 2013	Nov 17, 2013	Nov 17, 2013	Nov 17, 2013				
Time of sampling	10:10 AM	10:20 AM	10:50 AM	10:40 AM	10:30 AM				
All β	270,000	ND(17)	ND(17)	29	ND(17)				
H-3 (Approx. 12 years)	360,000	390	500	1,500	2,900				

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5
All β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5]	730 [11/7]	1,400 [11/13,11/15]	3,100 [11/10,11/13]

	E-6	E-7	E-8	E-10
All β	46 [9/20]	ND	17 [10/3]	28 [11/6]
H-3 (Approx. 12 years)	340 [9/25,10/9]	840 [10/9]	2,300 [11/13]	17,000 [11/13]

Unit: Bq/L, sampling date is provided in parentheses.

