

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
November 26, 2013
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area									
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10
Date of Sampling	Nov 24, 2013	Nov 24, 2013	Nov 24, 2013	Nov 24, 2013	Nov 24, 2013					
Time of sampling	11:54 AM	11:45 AM	11:38 AM	11:32 AM	11:25 AM					
All β	120,000	42	ND(18)	35	ND(18)					
H-3 (Approx. 12 years)	460,000	330	720	1,600	2,800					

* Data announced this time is provided in a thick-frame. The other data was announced on November 25.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5
All β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5]	730 [11/7]	1,600 [11/22]	3,100 [11/10,11/13]

	E-6	E-7	E-8	E-9	E-10
All β	46 [9/20]	ND	17 [10/3]	380 [11/25]	28 [11/6]
H-3 (Approx. 12 years)	340 [9/25,10/9]	840 [10/9]	2,300 [11/13]	Under analysis	17,000 [11/13]

Unit: Bq/L, sampling date is provided in parentheses.

