

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
November 29, 2013
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area										Well point	
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10		
Date of Sampling	Nov 27, 2013	Nov 27, 2013	Nov 27, 2013	Nov 27, 2013	Nov 27, 2013	Nov 27, 2013	Nov 27, 2013	Nov 27, 2013	Nov 27, 2013	Nov 27, 2013		Nov 27, 2013
Time of sampling	11:05 AM	10:55 AM	11:13 AM	10:25 AM	10:15 AM	9:40 AM	10:08 AM	9:58 AM	10:45 AM			11:18 AM
All β	14,000	ND(17)	18	33	ND(17)	ND(17)	ND(17)	ND(17)	290			12000
H-3 (Approx. 12 years)	62,000	340	700	1,400	2,500	150	530	2000	25,000			110,000

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5		
All β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]		
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5]	810 [11/25]	2,000 [11/25]	3,100 [11/10,11/13]		

	E-6	E-7	E-8	E-9	E-10	Well point
All β	46 [9/20]	ND	17 [10/3]	380 [11/25]	28 [11/6]	
H-3 (Approx. 12 years)	340 [9/25,10/9]	840 [10/9]	2,300 [11/13]	51,000 [11/25]	17,000 [11/13]	

Unit: Bq/L, sampling date is provided in parentheses.

