

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
December 24, 2013
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area										
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	Well point
Date of Sampling	Dec 22, 2013	Dec 22, 2013	Dec 22, 2013	Dec 22, 2013	Dec 22, 2013	/	/	/	/	/	/
Time of sampling	11:10 AM	11:20 AM	11:45 AM	11:00 AM	10:50 AM	/	/	/	/	/	/
Gross β	15,000	ND(19)	ND(19)	21	35	/	/	/	/	/	/
H-3 (Approx. 12 years)	11,000	410	660	1,200	2,100	/	/	/	/	/	/

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5
Gross β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5]	1,200 [12/18]	2,200 [12/7,12/16,12/18,12/21]	3,100 [11/10,11/13]

	E-6	E-7	E-8	E-9	E-10	Well point
Gross β	46 [9/20]	ND	17 [10/3]	380 [11/25]	28 [11/6]	16,000 [11/28]
H-3 (Approx. 12 years)	350 [12/18]	840 [10/9]	2,300 [11/13]	51,000 [11/25]	26,000 [12/19,12/21]	190,000 [11/30]

Unit: Bq/L, sampling date is provided in parentheses.

