

## Detailed Analysis Results of Grounwater Obtained around Unit 1-4 Building at Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

	Observation well										
	Sea side of the building							Mountain side of the building			
	Unit 1				Unit 2		Unit 4	Unit 1	Unit 2	Unit 3	Unit 4
	1T-1	1T-2	1T-3	1T-4	2T-1	2T-2	4T-1	1R-1	2R-1	3R-1	4R-1
Date of sampling	/							Sep 3, 2013			
Time of sampling	/							10:00 AM			
Cs-134 (Approx. 2 years)	/							ND(0.55)			
Cs-137 (Approx.30 years)	/							0.97			
The other γ	/							/			
	/							/			
	/							/			
All β	/							36			
H-3 (Approx. 12 years)	/							<b>31</b>			
Sr-90 (Approx. 29 years)	/							Under analysis			

\* Data announced this time is provided in a thick-frame. The other data was announced on September 4.

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

