

### Detailed Analysis Results of Grounwater Obtained around Unit 1-4 Building at Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

	Observation well													
	Sea side of the building								Mountain side of the building					
	Unit 1					Unit 2			Unit 4	Unit 1		Unit 2	Unit 3	Unit 4
	1T-1	1T-2	1T-3	1T-4	1T-5	2T-1	2T-2	4T-1	Test drilling hole N3	Test drilling hole N4	1R-1	2R-1	3R-1	4R-1
Date of sampling				Oct 11, 2013	Oct 11, 2013									
Time of sampling				10:35 AM	10:40 AM									
Cs-134 (Approx. 2 years)				ND(0.73)	ND(0.67)									
Cs-137 (Approx.30 years)				0.98	ND(0.74)									
The other γ														
All β				5000	8,500									
H-3 (Approx. 12 years)				2,500	12,000									
Sr-90 (Approx. 29 years)				Under analysis	Under analysis									

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

