

Detailed Analysis Results of Grounwater Obtained around Unit 1-4 Building at Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

		Mountain side of the building												
		Unit 1					Unit 2		Unit 3			Unit 4		
		N1	N2	N3	N4	N5	N6	N7	N8	N9	N10	N11	N12	N13
Date of sampling				Sep 1, 2013	Sep 1, 2013		Dec 2, 2013							
Time of sampling				11:00 AM	11:20 AM		11:00 AM							
Cs-134 (Approx. 2 years)				3.0	4.8		ND(0.75)							
Cs-137 (Approx.30 years)				7.2	12		ND(0.98)							
The other Y	Sb-125 (Approx. 3 years)			ND	32		ND							
All β				ND(21)	62		ND(15)							
H-3 (Approx. 12 years)				320	320		160							
Sr-90 (Approx. 29 years)				ND(0.34)	11		Under analysis							

* Data announced this time is provided in a thick-frame. The other data was announced on September 9.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

