

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
 (As of April 16, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes								
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧	
Sampled time	15:47	16:45	17:23	12:15	12:20	12:25	12:30									
Chloride concentration (ppm)	17	9	11	46	25	63	18	being drilled	being drilled	being drilled	being drilled					
Tritium (Bq/cm ³)	<2.6E-1	<2.6E-1	<2.6E-1	<2.3E-1	<2.3E-1	<2.3E-1	<2.3E-1									
All β(Bq/cm ³)	<1.1E-2	<1.1E-2	<1.1E-2	<7.9E-3	<7.9E-3	<7.9E-3	<7.9E-3									

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on April 17.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.