<Reference>
April 25, 2013
Tokyo Electric Power Company

Underground Reservoir Nuclide Analysis Results (As of April 17, 2013)

	Underground Reservoir (Drain hole water)													
	i		ii		iii		iv		v		vi		vii	
	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side
Sampled time	5:10 AM	5:10 AM	5:20 AM	5:20 AM	5:30 AM	5:30 AM	5:40 AM	5:40 AM	5:45 AM	5:45 AM	6:00 AM	6:00 AM	6:10 AM	6:10 AM
Tritium (Bq/cm^3)	2.1E+0	<2.4E-1	1.4E+0	<2.4E-1	<2.4E-1	<2.4E-1	6.4E-1	<2.4E-1	<2.5E-1	<2.5E-1	9.7E-1	2.6E-1	<2.5E-1	<2.5E-1

Half-life period Tritium: Approx. 12 years

	Underground Reservoir (Leakage detector hole water)													
	i		ii		iii		iv		v		vi		vii	
	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side
Sampled time	8:19 AM	8:26 AM	8:35 AM	8:40 AM	8:50 AM	8:52 AM	9:08 AM				9:25 AM			
Tritium (Bq/cm^3)	1.1E+3	<2.5E-1	4.3E+1	<2.5E-1	<2.5E-1	1.4E+1	<2.5E-1				<2.5E-1			

Half-life period Tritium: Approx. 12 years

(Note 1) O.OE±O is the same as O.O x $10^{\pm O}$.

(Note 2) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.

(Note 3) "ND" indicates that the measurement result of γ nuclides other than the major 3 nuclides are below the detection limit.