

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes  
 (As of May 6 and 7, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	May 7, 2013							May 6, 2013							
Sampled time	Not sampled	10:49 AM	9:28 AM	9:50 AM	9:55 AM	10:00 AM	10:05 AM	10:27 AM	11:15 AM	9:56 AM	10:34 AM	9:53 AM	11:24 AM	9:21 AM	11:57 AM
Chloride concentration (ppm)		9	12	17	62	90	12	8	7	10	10	8	9	17	8
Tritium (Bq/cm <sup>3</sup> )		1.5E-1	3.8E-2	<8.3E-3	<8.3E-3	<8.3E-3	4.9E-2	1.0E-1	5.4E-2	3.6E+0	1.0E+0	6.9E-2	9.2E-2	3.4E-2	5.8E-2
All β(Bq/cm <sup>3</sup> )		<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on May 7 and 8.

(Note 2) 0.0E±0 is the same as 0.0 x 10<sup>±0</sup>.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.