

Underground Reservoir Nuclide Analysis Results (As of June 21, 2013)

| | | Underground Reservoir (Drain hole water) | | | | | | | | | | | | | |
|--|--|--|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| | | i | | ii | | iii | | iv | | v | | vi | | vii | |
| | | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side |
| Sampled time | | 8:25 AM | 8:35 AM | 8:19 AM | 8:29 AM | 8:14 AM | 8:23 AM | 8:09 AM | 8:14 AM | 8:15 AM | 8:10 AM | 8:28 AM | 8:20 AM | 8:35 AM | 8:40 AM |
| Chloride concentration (ppm) | | 12 | 7 | 10 | 9 | 10 | 5 | 11 | 10 | 10 | 8 | 11 | 11 | 7 | 10 |
| Radioactive concentration (Bq/cm ³) | I-131 | <2.5E-2 | <2.9E-2 | <2.4E-2 | <2.9E-2 | <2.7E-2 | <2.1E-2 | <2.8E-2 | <2.5E-2 | <2.7E-2 | <2.5E-2 | <2.2E-2 | <2.1E-2 | <2.2E-2 | <2.4E-2 |
| | Cs-134 | <4.8E-2 | <5.1E-2 | <5.2E-2 | <5.0E-2 | <4.7E-2 | <4.7E-2 | <5.3E-2 | <4.7E-2 | <5.4E-2 | <5.0E-2 | <4.8E-2 | <5.1E-2 | <5.0E-2 | <5.1E-2 |
| | Cs-137 | <6.6E-2 | <6.8E-2 | <6.4E-2 | <6.7E-2 | <6.7E-2 | <6.8E-2 | <6.5E-2 | <6.7E-2 | <6.4E-2 | <6.8E-2 | <6.5E-2 | <6.8E-2 | <6.7E-2 | <6.9E-2 |
| | γ nuclides other than the major 3 nuclides | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | All β | 5.4E+0 | <3.0E-2 | 2.5E-1 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | 8.7E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 |

Half-life period I-131: Approx. 8 days, Cs-134: Approx. 2 years, Cs-137: Approx. 30 years

| | | Underground Reservoir (Leakage detector hole water) | | | | | | | | | | | | | |
|--|--|---|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| | | i | | ii | | iii | | iv | | v | | vi | | vii | |
| | | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side |
| Sampled time | | 8:00 AM | 8:05 AM | 8:05 AM | 8:13 AM | 8:10 AM | 8:19 AM | 8:04 AM | Not sampled | | | 8:25 AM | Not sampled | | |
| Chloride concentration (ppm) | | 17 | 6 | 32 | 10 | 9 | 9 | 9 | | | | 5 | | | |
| Radioactive concentration (Bq/cm ³) | I-131 | <3.1E-2 | <2.8E-2 | <3.3E-2 | <3.3E-2 | <2.8E-2 | <2.5E-2 | <2.9E-2 | | | | <2.3E-2 | | | |
| | Cs-134 | <5.8E-2 | <4.9E-2 | <5.1E-2 | <4.9E-2 | <4.6E-2 | <4.8E-2 | <5.0E-2 | | | | <5.0E-2 | | | |
| | Cs-137 | <6.5E-2 | <6.8E-2 | <6.6E-2 | <6.7E-2 | <6.5E-2 | <6.8E-2 | <6.9E-2 | | | | <6.7E-2 | | | |
| | γ nuclides other than the major 3 nuclides | 1.0E-1* | ND | ND | ND | ND | ND | ND | | | | ND | | | |
| | All β | 3.1E+2 | <3.0E-2 | 4.6E+2 | <3.0E-2 | <3.0E-2 | 7.3E+0 | <3.0E-2 | | | | <3.0E-2 | | | |

Half-life period I-131: Approx. 8 days, Cs-134: Approx. 2 years, Cs-137: Approx. 30 years

* Sb-125: 1.0E-1

(Note 1) 0.OE±0 is the same as 0.O x 10^{±0}.

(Note 2) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.

(Note 3) "ND" indicates that the measurement result of γ nuclides other than the major 3 nuclides are below the detection limit.

Underground Reservoir Observation Holes Nuclide Analysis Results (As of June 21, 2013)

| | Underground reservoir observation holes (i - iii) | | | | | | | | | | | | | |
|-----------------------------------|---|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | A1 | A2 | A3 | A4 | A5 | A6 | A7 | A8 | A9 | A10 | A11 | A12 | A13 | A14 |
| Sampled time | 8:36 AM | 8:44 AM | 8:54 AM | 8:33 AM | 8:44 AM | 8:51 AM | 9:00 AM | 9:07 AM | 9:32 AM | 9:15 AM | 9:23 AM | 8:58 AM | 9:05 AM | 9:14 AM |
| Chloride concentration (ppm) | 9 | 10 | 10 | 8 | 8 | 7 | 7 | 9 | 9 | 9 | 36 | 8 | 8 | 10 |
| All β (Bq/cm ³) | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 |

| | Underground reservoir observation holes (i - iii) | | | | | Underground reservoir observation holes (vi) | | |
|-----------------------------------|---|---------|---------|---------|---------|--|---------|---------|
| | A15 | A16 | A17 | A18 | A19 | B1 | B2 | B3 |
| Sampled time | 9:24 AM | 9:33 AM | 9:41 AM | 8:36 AM | 8:48 AM | 9:18 AM | 9:30 AM | 9:42 AM |
| Chloride concentration (ppm) | 8 | 13 | 8 | 7 | 9 | 24 | 4 | 8 |
| All β (Bq/cm ³) | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 | <3.0E-2 |

(Note 1) 0.0E±0 is the same as 0.0 x 10^{±0}.

(Note 2) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.