

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of June 24 and 25, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Jun 25, 2013										Jun 24, 2013				
Sampled time	Not sampled	10:22 AM	9:50 AM	10:40 AM	10:40 AM	10:40 AM	10:40 AM	9:16 AM	9:56 AM	9:23 AM	11:10 AM	9:32 AM	9:28 AM	10:03 AM	10:16 AM
Chloride concentration (ppm)		9	12	14	42	80	14	10	10	10	11	9	8	16	11
Tritium (Bq/cm ³)		1.2E-1	<7.4E-3	1.6E-2	2.9E-2	1.1E-2	4.3E-2	7.9E-2	7.7E-2	3.2E+0	8.2E-1	6.6E-2	8.4E-2	3.5E-2	6.8E-2
All β(Bq/cm ³)		<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on June 25 and 26.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.