

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of July 8 and 9, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes								
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧	
	Jul 9, 2013								Jul 8, 2013							
Sampled time	Not sampled	10:15 AM	9:49 AM	10:00 AM	10:00 AM	10:00 AM	10:00 AM	9:19 AM	9:46 AM	9:25 AM	10:25 AM	9:56 AM	9:27 AM	10:21 AM	10:03 AM	
Chloride concentration (ppm)		8	10	13	50	83	10	8	9	9	9	7	12	16	6	
Tritium (Bq/cm ³)		1.0E-1	<7.3E-3	1.8E-2	2.7E-2	<7.3E-3	3.9E-2	8.6E-2	9.1E-2	2.9E+0	9.2E-1	7.0E-2	9.4E-2	3.7E-2	6.2E-2	
All β(Bq/cm ³)		<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on July 9 and 10.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.