

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes  
(As of July 22 and 23, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Jul 23, 2013										Jul 22, 2013				
Sampled time	Not sampled	10:18 AM	9:51 AM	10:00 AM	10:00 AM	10:00 AM	10:00 AM	9:11 AM	9:38 AM	9:23 AM	10:20 AM	10:29 AM	10:06 AM	10:31 AM	9:46 AM
Chloride concentration (ppm)		9	11	27	68	85	10	9	6	8	10	8	10	17	8
Tritium (Bq/cm <sup>3</sup> )		9.8E-2	<8.2E-3	3.1E-2	1.4E-2	<8.4E-3	4.3E-2	8.0E-2	2.9E-2	2.4E+0	1.1E+0	7.3E-2	8.8E-2	4.0E-2	5.3E-2
All β(Bq/cm <sup>3</sup> )		<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on July 23 and 24.

(Note 2) O.OE±O is the same as O.O x 10<sup>±0</sup>.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.