

Underground Reservoir Tritium Analysis Results (As of July 24, 2013)

| | Underground Reservoir (Drain hole water) | | | | | | | | | | | | | |
|-------------------------------|--|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| | i | | ii | | iii | | iv | | v | | vi | | vii | |
| | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side |
| Sampled time | 8:16 AM | 8:35 AM | 8:08 AM | 8:30 AM | 8:02 AM | 8:20 AM | 7:58 AM | 8:06 AM | Out of range | Out of range | 8:09 AM | 7:57 AM | Out of range | Out of range |
| Tritium (Bq/cm ³) | 4.7E-1 | <2.4E-1 | <2.4E-1 | <2.4E-1 | <2.4E-1 | <2.4E-1 | 1.5E+0 | <2.4E-1 | | | 3.2E-1 | <2.4E-1 | | |

Half-life period Tritium: Approx. 12 years

| | Underground Reservoir (Leakage detector hole water) | | | | | | | | | | | | | |
|-------------------------------|---|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| | i | | ii | | iii | | iv | | v | | vi | | vii | |
| | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side |
| Sampled time | 7:42 AM | 7:55 AM | 7:48 AM | 8:05 AM | 7:56 AM | 8:15 AM | 7:50 AM | Not sampled | | | 8:03 AM | Not sampled | | |
| Tritium (Bq/cm ³) | 1.2E+0 | <2.4E-1 | 7.8E-1 | <2.4E-1 | <2.4E-1 | 4.7E-1 | <2.4E-1 | | | | <2.4E-1 | | | |

Half-life period Tritium: Approx. 12 years

(Note 1) Analysis of tritium is conducted once a week.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.