

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of September 2 and 3, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Sep 3, 2013										Sep 2, 2013				
Sampled time	Not sampled	10:15 AM	9:51 AM	8:15 AM	8:20 AM	8:25 AM	8:30 AM	9:11 AM	9:38 AM	9:24 AM	10:12 AM	9:41 AM	9:54 AM	11:35 AM	9:30 AM
Chloride concentration (ppm)		9	11	53	82	86	8	9	5	8	10	9	10	16	10
Tritium (Bq/cm ³)		8.5E-2	<8.0E-3	1.2E-2	1.6E-2	1.1E-2	9.8E-2	7.8E-2	4.4E-2	2.1E+0	1.5E+0	7.2E-2	8.8E-2	5.4E-2	7.0E-2
All β(Bq/cm ³)		<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on September 2 and 3.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.