

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of September 9 and 10, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Sep 10, 2013										Sep 9, 2013				
Sampled time	Not sampled	10:00 AM	9:39 AM	10:00 AM	10:05 AM	10:10 AM	10:15 AM	9:10 AM	9:42 AM	9:17 AM	10:52 AM	9:20 AM	9:41 AM	9:44 AM	9:20 AM
Chloride concentration (ppm)		9	11	36	74	60	9	9	6	8	10	8	10	16	12
Tritium (Bq/cm ³)		1.2E-1	<7.9E-3	8.9E-3	1.1E-2	<6.1E-3	4.7E-2	7.7E-2	4.9E-2	1.9E+0	1.6E+0	7.5E-2	9.5E-2	4.5E-2	5.6E-2
All β(Bq/cm ³)		<3.0E-2	<3.0E-2	<1.5E-2	<1.5E-2	<1.5E-2	<1.5E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on September 10 and 11.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.