

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of October 14 and 15, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Oct 15, 2013										Oct 14, 2013				
Sampled time	Not sampled	9:47 AM	9:23 AM	11:00 AM	11:07 AM	11:12 AM	11:18 AM	8:48 AM	9:18 AM	9:00 AM	9:59 AM	8:42 AM	8:37 AM	9:00 AM	9:05 AM
Chloride concentration (ppm)		9	11	16	70	90	11	9	6	10	12	8	12	18	8
Tritium (Bq/cm ³)		9.4E-2	5.2E-3	1.4E-2	1.3E-2	<5.4E-3	4.7E-2	8.3E-2	3.8E-2	1.4E+0	2.8E+0	6.4E-2	8.4E-2	3.6E-2	5.2E-2
All β(Bq/cm ³)		<2.8E-2	<2.8E-2	<1.5E-2	<1.5E-2	<1.5E-2	<1.5E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on October 15 and 16.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.