

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of October 28 and 29, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Oct 29, 2013										Oct 28, 2013				
Sampled time	Not sampled	9:45 AM	9:27 AM	10:08 AM	10:11 AM	10:14 AM	10:17 AM	8:56 AM	9:16 AM	9:02 AM	10:05 AM	8:47 AM	9:07 AM	9:09 AM	9:38 AM
Chloride concentration (ppm)		9	11	40	60	84	7	9	6	7	10	7	11	21	8
Tritium (Bq/cm ³)		1.6E-1	1.0E-2	<5.6E-3	7.1E-3	<5.6E-3	3.0E-2	7.6E-2	4.4E-2	1.4E+0	2.9E+0	7.0E-2	8.8E-2	3.6E-2	6.1E-2
All β(Bq/cm ³)		<2.8E-2	<2.8E-2	<1.7E-2	<1.7E-2	<1.7E-2	<1.7E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on October 29 and 30.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.