

Underground Reservoir Nuclide Analysis Results (As of November 15, 2013)

		Underground Reservoir (Drain hole water)													
		i		ii		iii		iv		v		vi		vii	
		Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side
Sampled time		8:18 AM	8:31 AM	8:04 AM	8:24 AM	8:00 AM	8:07 AM	7:54 AM	8:00 AM	8:12 AM	8:09 AM	8:22 AM	8:15 AM	8:26 AM	8:37 AM
Chloride concentration (ppm)		9	6	9	7	8	7	11	18	8	4	9	8	5	8
Radioactive concentration (Bq/cm ³)	I-131	<2.7E-2	<2.4E-2	<2.7E-2	<2.5E-2	<2.5E-2	<2.7E-2	<3.1E-2	<2.8E-2	<2.6E-2	<2.8E-2	<3.1E-2	<2.0E-2	<2.3E-2	<2.7E-2
	Cs-134	<4.8E-2	<4.6E-2	<4.6E-2	<4.6E-2	<4.5E-2	<4.7E-2	<5.1E-2	<5.3E-2	<4.9E-2	<4.5E-2	<4.6E-2	<4.6E-2	<4.6E-2	<4.4E-2
	Cs-137	<6.5E-2	<6.5E-2	<6.6E-2	<6.5E-2	<6.6E-2	<6.4E-2	<6.7E-2	<6.4E-2	<6.4E-2	<6.5E-2	<6.5E-2	<6.4E-2	<6.6E-2	<6.5E-2
	γ nuclides other than the major 3 nuclides	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	All β	9.1E-1	<2.8E-2	3.0E-2	<2.8E-2	1.2E-1	4.3E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	5.4E-2	<2.8E-2	<2.8E-2	<2.8E-2

Half-life period I-131: Approx. 8 days, Cs-134: Approx. 2 years, Cs-137: Approx. 30 years

		Underground Reservoir (Leakage detector hole water)													
		i		ii		iii		iv		v		vi		vii	
		Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side
Sampled time		7:50 AM	8:28 AM	7:54 AM	8:21 AM	7:58 AM	8:12 AM	7:57 AM	Not sampled			8:18 AM	Not sampled	8:30 AM	8:34 AM
Chloride concentration (ppm)		15	6	11	17	10	10	11				9		7	7
Radioactive concentration (Bq/cm ³)	I-131	<3.1E-2	<2.5E-2	<2.7E-2	<2.6E-2	<2.6E-2	<2.7E-2	<2.6E-2				<2.4E-2		<2.8E-2	<2.2E-2
	Cs-134	<4.9E-2	<4.6E-2	<4.8E-2	<4.5E-2	<4.6E-2	<4.7E-2	<4.9E-2				<4.4E-2		<4.6E-2	<4.8E-2
	Cs-137	<6.5E-2	<6.4E-2	<6.5E-2	<6.5E-2	<6.4E-2	<6.6E-2	<6.8E-2				<6.5E-2		<6.5E-2	<6.6E-2
	γ nuclides other than the major 3 nuclides	ND	ND	ND	ND	ND	ND	ND				ND		ND	ND
	All β	2.3E+2	<2.8E-2	2.6E+1	<2.8E-2	1.3E+0	3.8E+1	<2.8E-2				<2.8E-2		<2.8E-2	<2.8E-2

Half-life period I-131: Approx. 8 days, Cs-134: Approx. 2 years, Cs-137: Approx. 30 years

(Note 1) O.OE±O is the same as O.O x 10^{±0}.

(Note 2) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.

(Note 3) "ND" indicates that the measurement result of γ nuclides other than the major 3 nuclides are below the detection limit.

Underground Reservoir Observation Holes Nuclide Analysis Results (As of November 15, 2013)

	Underground reservoir observation holes (i - iii)													
	A1	A2	A3	A4	A5	A6	A7	A8	A9	A10	A11	A12	A13	A14
Sampled time	8:19 AM	8:29 AM	8:39 AM	8:50 AM	9:22 AM	8:56 AM	8:49 AM	8:42 AM	8:37 AM	8:31 AM	9:28 AM	9:19 AM	9:10 AM	9:01 AM
Chloride concentration (ppm)	8	10	11	7	9	8	9	9	10	14	35	10	10	15
All β (Bq/cm ³)	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2

	Underground reservoir observation holes (i - iii)					Underground reservoir observation holes (vi)		
	A15	A16	A17	A18	A19	B1	B2	B3
Sampled time	8:53 AM	8:44 AM	8:35 AM	9:14 AM	9:05 AM	9:08 AM	9:18 AM	9:29 AM
Chloride concentration (ppm)	9	13	5	7	10	18	5	9
All β (Bq/cm ³)	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2

(Note 1) O.OE±O is the same as O.O x 10^{±0}.

(Note 2) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.