

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of November 11 and 12, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Nov 12, 2013										Nov 11, 2013				
Sampled time	Not sampled	9:34 AM	9:14 AM	9:46 AM	9:50 AM	9:53 AM	9:56 AM	8:52 AM	9:09 AM	8:55 AM	9:32 AM	8:51 AM	8:50 AM	9:15 AM	9:12 AM
Chloride concentration (ppm)		10	11	44	65	85	10	9	5	8	10	6	10	23	10
Tritium (Bq/cm ³)		2.6E-1	7.0E-3	1.6E-2	5.1E-3	<4.7E-3	3.9E-2	9.5E-2	8.0E-2	1.2E+0	2.7E+0	6.1E-2	7.8E-2	3.2E-2	5.0E-2
All β(Bq/cm ³)		<2.8E-2	<2.8E-2	<1.5E-2	<1.5E-2	<1.5E-2	<1.5E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on November 12 and 13.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.