

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of November 25 and 26, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Nov 26, 2013										Nov 25, 2013				
Sampled time	Not sampled	9:47 AM	9:23 AM	9:47 AM	9:49 AM	9:52 AM	9:55 AM	8:52 AM	9:09 AM	8:59 AM	9:41 AM	8:58 AM	8:50 AM	9:21 AM	9:12 AM
Chloride concentration (ppm)		10	11	19	72	80	10	9	5	7	11	7	10	16	9
Tritium (Bq/cm ³)		4.8E-1	<9.9E-3	4.0E-2	1.3E-2	6.8E-3	5.0E-2	5.9E-2	4.6E-2	1.1E+0	3.1E+0	7.3E-2	7.1E-2	4.1E-2	7.6E-2
All β(Bq/cm ³)		<3.0E-2	<3.0E-2	<1.5E-2	<1.5E-2	<1.5E-2	<1.5E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on November 26 and 27.

(Note 2) 0.0E±0 is the same as 0.0 x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.