

Reference

Nuclide Analysis of the Radioactive Materials in the Fallouts obtained inside and outside of Fukushima Daiichi Nuclear Power Station

	Sampling Point		Sampling Period		Radioactivity Density of Samples (Bq/m ²) (Half-life)		
			From	To	I-131 (approx. 8 days)	Cs-134 (approx. 2 years)	Cs-137 (approx. 30 years)
Fukushima Daiichi NPS		Environment Management Building	2013/6/3 12:15 PM	2013/7/1 1:10 PM	ND	930	2000
Fukushima Daini NPS		Administrative Office Building	2013/6/3 2:00 PM	2013/7/1 10:45 AM	ND	17	33

* Bq/m² = MBq/km²

* "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 48Bq/m²

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.