

Gas Sampling Results of Unit 1 PCV Gas Control System Conducted at Fukushima Daiichi Nuclear Power Station

(Data summarized on July 10)

| | | | | |
|----------------------------------|--|--|--|--|
| Place of Sampling | Exit of Unit 1 PCV Gas Control System | | | |
| Type of Sampling | Particulate Filter | | Charcoal Filter | |
| Time of Sampling | Jul 1, 2013 10:11 AM - 10:51 AM | | Jul 1, 2013 10:11 AM - 10:51 AM | |
| Detected Nuclides (Half-life) | Density of Sample (Bq/cm ³) | Detection Limit Density (Bq/cm ³) | Density of Sample (Bq/cm ³) | Detection Limit Density (Bq/cm ³) |
| I-131 (Approx. 8 days) | ND | 5.7E-07 | ND | 1.0E-06 |
| Cs-134 (Approx. 2 years) | ND | 1.2E-06 | ND | 2.3E-06 |
| Cs-137 (Approx. 30 years) | ND | 1.7E-06 | ND | 3.2E-06 |

* 0.0E-0 is the same as 0.0 x 10⁰

* "ND" indicates that the measurement result is below the detection limit.

This sampling is intended for the nuclides analysis result of cesium and iodine.