

Gas Sampling Results of Unit 2 PCV Gas Control System Conducted at Fukushima Daiichi Nuclear Power Station

(Data summarized on September 30)

| | | | | |
|----------------------------------|--|--|--|--|
| Place of Sampling | Exit of Unit 2 PCV Gas Control System | | | |
| Type of Sampling | Particulate Filter | | Charcoal Filter | |
| Time of Sampling | Sep 12, 2013 11:17 AM - 11:27 AM | | Sep 12, 2013 11:27 AM - 11:57 AM | |
| Detected Nuclides (Half-life) | Density of Sample (Bq/cm ³) | Detection Limit Density (Bq/cm ³) | Density of Sample (Bq/cm ³) | Detection Limit Density (Bq/cm ³) |
| I-131 (Approx. 8 days) | ND | 9.0E-07 | ND | 6.0E-07 |
| Cs-134 (Approx. 2 years) | ND | 2.1E-06 | ND | 1.2E-06 |
| Cs-137 (Approx. 30 years) | ND | 2.9E-06 | ND | 1.7E-06 |

* O.OE - O is the same as O.O x 10^{-O}

* "ND" indicates that the measurement result is below the detection limit.

This sampling is intended for the nuclides analysis result of cesium and iodine.