

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

	Pump wells of the groundwater bypass			
	No.7	No.8	No.9	No.10
Date of Sampling	Aug 29, 2013	Aug 29, 2013	Aug 29, 2013	Aug 29, 2013
Time of sampling	10:50 AM	10:45 AM	10:40 AM	10:35 AM
All $\beta$	ND(16)	ND(16)	ND(16)	ND(16)
Tritium	470	56	38	290

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.