

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

	Pump wells of the groundwater bypass	
	No.11	No.12
Date of Sampling	Aug 30, 2013	Aug 30, 2013
Time of sampling	2:20 PM	2:25 PM
All β	ND(16)	ND(16)
Tritium	300	900

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.