

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

	Groundwater around H4 area				
	E-1	E-2	E-3	E-4	E-5
Date of Sampling	/	Sep 4, 2013	/	/	/
Time of sampling	/	11:40 AM	/	/	/
All $\beta$	/	650	/	/	/
H-3 (Approx. 12 years)	/	ND(120)	/	/	/

\* Data announced this time is provided in a thick-frame. The other data was announced on September 5.

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

