

Nuclides Analysis Result of the Radioactive Materials in the Seawater < Offshore of Ibaraki Prefecture >

Reference

(Data summarized on May 30)

Place of Sampling (Place No.)	3km Offshore of Takadokobama Shore (T-A)				3km Offshore of Kujihama Shore (T-B)				3km Offshore of Oarai Shore (T-C)				Density Limit Specified by the Reactor Regulation (Bq/L) (The density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2.)
	Upper Layer		Lower Layer		Upper Layer		Lower Layer		Upper Layer		Lower Layer		
Time of Sampling	May 14, 2013 7:19 AM		May 14, 2013 7:19 AM		May 15, 2013 7:44 AM		May 15, 2013 7:42 AM		May 15, 2013 8:30 AM		May 15, 2013 8:27 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
Cs-134 (Approx. 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (Approx. 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

Place of Sampling (Place No.)	3km Offshore of Hirai Shore (T-D)				3km Offshore of Hasaki Shore (T-E)				3km Offshore of Isohara Shore (T-Z)				Density Limit Specified by the Reactor Regulation (Bq/L) (The density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2.)
	Upper Layer		Lower Layer		Upper Layer		Lower Layer		Upper Layer		Lower Layer		
Time of Sampling	May 14, 2013 3:20 PM		May 14, 2013 3:18 PM		May 14, 2013 1:42 PM		May 14, 2013 1:41 PM		May 14, 2013 9:01 AM		May 14, 2013 9:01 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
Cs-134 (Approx. 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (Approx. 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

* The density specified by the Reactor Regulation is converted from Bq/cm³ to Bq/L.

* Data of other nuclides is under evaluation.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

Cs-134: Approx.1.2Bq/L, Cs-137: Approx.1.2Bq/L

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.