

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

Unit: Bq/L

	Pump wells of the groundwater bypass											
	No.1	No.2	No.3	No.4	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013	Oct 8, 2013
Time of sampling	10:33 AM	10:40 AM	10:50 AM	10:58 AM	11:20 AM	11:33 AM	11:44 AM	12:00 PM	12:09 PM	12:15 PM	12:30 PM	12:36 PM
Cs-134(Approx. 2 years)	ND(0.55)	ND(0.75)	ND(0.47)	ND(0.54)	ND(0.67)	ND(0.59)	ND(0.44)	ND(0.69)	ND(0.83)	ND(0.65)	ND(0.65)	ND(0.48)
Cs-137(Approx.30 years)	ND(0.57)	ND(0.71)	ND(0.80)	ND(0.81)	ND(0.69)	ND(0.45)	ND(0.71)	ND(0.72)	ND(0.98)	ND(0.82)	ND(0.70)	ND(0.80)
All β *	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis

* Data of all β obtained at the pump wells No.1 to No.4 was announced on October 10.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

