

# Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

<Reference>  
November 14, 2013  
Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass							
	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Nov 12, 2013	Nov 12, 2013	Nov 12, 2013	Nov 12, 2013	Nov 12, 2013	Nov 12, 2013	Nov 12, 2013	Nov 12, 2013
Time of sampling	10:07 AM	10:12 AM	10:16 AM	10:21 AM	10:25 AM	10:28 AM	10:40 AM	10:45 AM
All $\beta$	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)
H-3 (Approx. 12 years)	28	120	610	69	76	280	460	740

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	No.5	No.6	No.7	No.8
All $\beta$	ND	ND	ND	ND
H-3 (Approx. 12 years)	41 [11/5]	160 [10/22]	570 [9/4]	71 [9/3]

	No.9	No.10	No.11	No.12
All $\beta$	ND	ND	ND	ND
H-3 (Approx. 12 years)	67 [11/5]	330 [9/1,9/2]	480 [10/22,11/5]	910 [9/1]

Unit: Bq/L, sampling date is provided in parentheses.

