

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

<Reference>
December 26, 2013
Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass							
	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Dec 24, 2013	Dec 24, 2013	Dec 24, 2013	Dec 24, 2013	Dec 24, 2013	Dec 24, 2013	Dec 24, 2013	Dec 24, 2013
Time of sampling	10:46 AM	10:49 AM	10:53 AM	10:56 AM	11:00 AM	11:05 AM	11:12 AM	11:16 AM
All β	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)
H-3 (Approx. 12 years)	25	120	540	80	92	190	300	1000

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	No.5	No.6	No.7	No.8
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	41 [11/5]	160 [10/22]	620 [11/19]	97 [11/26]

	No.9	No.10	No.11	No.12
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	100 [11/26,12/3]	330 [9/1,9/2]	480 [10/22,11/5]	910 [9/1]

Unit: Bq/L, sampling date is provided in parentheses.

