

Measurement Results of the Seawater Sampled at Yotsukura Beach and Nakoso Beach

<Reference>
August 1, 2013
Tokyo Electric Power Company

1. Sampling Location

- (1) 2 locations at Yotsukura beach (North side, South side)
- (2) 3 locations at Nakoso beach (North side, Central part, South side)

2. Sampling method

Seawater is sampled directly from sea surface (surface layer) and 0.1m from the bottom of the sea (lower layer) at the location of approx. 1.0m deep.

Unit: Bq/L

		Yotsukura beach				Nakoso beach					
		North side, surface layer	North side, lower layer	South side, surface layer	South side, lower layer	North side, surface layer	North side, lower layer	Central part, surface layer	Central part, lower layer	South side, surface layer	South side, lower layer
Date of sampling		Jul 30, 2013				Jul 30, 2013					
Time of sampling		3:15 PM	3:15 PM	3:30 PM	3:30 PM	1:15 PM	1:15 PM	1:30 PM	1:30 PM	1:45 PM	1:45 PM
Cs-134	Density	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Detection limit	0.96	1.3	1.4	1.3	1.2	1.4	1.3	1.2	1.4	1.2
Cs-137	Density	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Detection limit	1.2	1.1	1.4	1.2	1.2	1.3	0.92	1.1	1.3	1.0
All β	Density	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Detection limit	20	20	20	20	20	20	20	20	20	20
Tritium	Density	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	Detection limit	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6

(Note) "ND" indicates that the measurement result is below the detection limit

Analysis method of the samples obtained on July 30 at the beaches

Object item	Analysis method	Operation manual, etc.
Cesium	γ ray spectrometry (No pre-treatment, measured directly)	"Guideline Regarding the Measurement of the Emitted Radioactive Material at the Power Generation Light Water Reactor Facilities" (Nuclear Safety Commission)
All β	Evaporation to dryness method	"Guideline Regarding the Measurement of the Emitted Radioactive Material at the Power Generation Light Water Reactor Facilities" (Nuclear Safety Commission)
Tritium	Distillation method	"Guideline Regarding the Measurement of the Emitted Radioactive Material at the Power Generation Light Water Reactor Facilities" (Nuclear Safety Commission)

[Reference] Standard value

Unit: Bq/L

	Cesium 134	Cesium 137	Strontium 90	Tritium
Density limit specified by regulation ^{*1}	60	90	30	60,000
WHO guidelines for drinking water quality	10	10	10	10,000
Radioactive materials in food (Drinking water)	10 ^{*2}		-	-
Guidelines regarding radioactive materials in the bathing area	10 ^{*2}		-	-

*1 Density of the radioactive material in the water obtained at the outside of the border of a surrounding supervised area at the power station.

*2 Prescribed as total density of Cs-134 and Cs-137.