Reference

## Nuclides Analysis Result of the Radioactive Materials in the Seawater < Coast, Fukushima Daiichi Nuclear Power Station >

(Data summarized on April 10)

Place of Sampling	North of Unit 5-6 Discharge Channel at Fukushima Daiichi NPS (Approx. 30m North of Unit 5-6 Discharge Channel)		Around South Discharge Channel of Fukushima Daiichi NPS (Appox. 1.3km South of Unit 1-4 Discharge Channel)		Density Limit Specified by the Reactor Regulation (Bq/L) (The density limit in the water outside the surrounding monitored areas is provided in
Time of Sampling	Apr 9, 2013 6:55 AM		Apr 9, 2013 7:30 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor	Density of Sample (Bq/L)	Scaling Factor	section 6 of Appendix 2.)
I-131 (Approx. 8 days)	ND	-	ND	-	40
Cs-134 (Approx. 2 years)	ND	-	ND	-	60
Cs-137 (Approx. 30 years)	ND	-	ND	-	90

<sup>\*</sup> The density specified by the Reactor Regulation is converted from Bq/cm<sup>3</sup> to Bq/L.

I-131: Approx. 0.41Bq/L, Cs-134: Approx. 1.0Bq/L, Cs-137: Approx. 1.4Bq/L


As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

<sup>\*</sup> Data of other nuclides is under evaluation.

<sup>\*</sup> In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

 $<sup>^{\</sup>star}$  "ND" indicates that the measurement result is below the detection limit.

## Radioactivity Density of the Seawater at 1F Units 5-6 North Discharge Channel (Bq/L)



## Radioactivity Density of the Seawater at 1F South Discharge Channel (Bq/L)

