

Analysis Results on Seawater of the South Water Outlet (Near the Exit of the Side Ditch) at Fukushima Daiichi NPS

Unit: Bq/L

	Seawater of the south water outlet (near the exit of the side ditch)	Water of the side ditch in front of the core warehouse
Date of Sampling	Aug 20, 2013	Aug 20, 2013
Time of sampling	2:20 PM	11:40 AM
Cs-134(Approx. 2 years)	ND(1.1)	ND(19)
Cs-137(Approx.30 years)	1.8	ND(27)
All β	ND(19)	93

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.